



rfo-sfps-vadodara@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOVAD/2023/00037681

Date: 02/08/2024

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOVAD/2023/00037681/R1

Building Occupancy/Category: Institutional (Hospital, Correctional Facility, Care Centers etc.)

To,

JADAV MAYURKUMAR SATISHKUMAR

Derol Station Road Derol Station Road Kalol Kalol KALOL Panchmahals 389330

Fire Region: Vadodara RFO

Mobile No: 9825217072 Email ID: mayur.jadav5191@gmail.com

This has reference to your Application No. 2024/00076883 dated 01/08/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise Sanjeevani Hospital (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Kalol
5. Name of Block(s): Sanjeevani Hospital

The building/premise was inspected on 02/08/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 02/08/2024
2. Six monthly inspection was done on 02/08/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 02/08/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Mayurkumar Satishkumar Jadav
Fire Safety Officer - General (FSO-G)
2021/001731

Date: 02/08/2024
Time: 04:03 PM



FSCA/O/RFOVAD/2023/00037681/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.